



**THE CITY OF MARIETTA
MARIETTA, GEORGIA**

**June 7, 2013
ADDENDUM NO. 1
TO
CITY OF MARIETTA BID NO. RFB-13-34380
CITY HALL PARKING DECK REPAIRS**

Change or add the following in the above referenced bid

Questions:

- 1. What are the details for the tie back anchorage on the NE corner stairs/walls?**

See revised drawing sheet #2 for detail drawing for installation of Atlas Piers.

- 2. How should we handle mobilization costs?**

Mobilization costs should be added as a separate line item on revised bid document.

- 3. How should we handle general conditions?**

General Conditions should be added as a separate line item on revised bid document.

- 4. Are you replacing any of the rebar?**

Replacement of the rebar is not part of the bid. If necessary, it will be handled as a change order at the time of repair, as approved by owner.

- 5. What is the required warranty period given that the top deck will not be sealed as part of the project?**

A warranty period of one (1) year is required.

- 6. Who will be responsible for moving electrical conduit and light fixtures if required to complete the work?**

The contractor shall be responsible for the temporary removal, relocation, or rerouting of the conduit and/or lighting fixtures and shall include this cost in the patching price.

The bid opening will be extended to Friday, June 14 at the same time and place stipulated in the RFB document.



City of Marietta
Purchasing Department
205 Lawrence Street
Marietta, GA 30060

REVISED BID FORM

CITY OF MARIETTA/BOARD OF LIGHTS AND WATER
CITY HALL PARKING DECK REPAIRS
RFB-13-34380

<u>LINE ITEM</u>	<u>DESCRIPTION</u>	<u>Unit</u>	<u>Estimate Quantity</u>	<u>Unit Price</u>	<u>TOTAL PRICE</u>
1	Provide materials and labor for Task I. REPAIRS TO TRANSVERSE CRACKING AND SPALLING IN UNDERSIDE OF THE PARKING DECK SLAB	LF	1040		
2	Provide materials and labor for Task II. REPAIRS TO CRACKS IN THE MAIN BEAMS ALONG EACH SIDE OF THE RAMP TO THE UPPER LEVEL.	LF	135		
3	Provide materials and labor for Task III. REPAIRS TO LONGITUDINAL CRACK IN THE ON-GRADE PORTION OF THE UP RAMP.	LF	570		
4	Provide materials and labor for Task IV. REPAIRS TO CRACKS, SPALLING AND STABILIZATION OF THE STAIRS AT THE NE CORNER OF THE DECK.	Piers each	3		
		Crack and spalling repair			
5	Provide materials and labor for Task V. STABILIZATION OF THE WALL AT THE NW CORNER OF THE DECK.	Counterfor t And piers	2		
		Crack repair			
6	Mobilization expense	Each	1		
7	General Conditions	Each	1		

Total Value of Unit Items (Base Bid)

\$ _____

Bid submitted by:

Company Name: _____

Address: _____

City, State, Zip: _____

Authorized Signature: _____

Print Name: _____

Telephone: _____ Fax: _____

Date _____





e-mail _____


tax id number _____

Sign below and include in your bid package to indicate that you received this addendum.

Vendor Name

Signature



2 OF 2		2 OF 2 NO SCALE SHEET 2012
BY: <u> </u>	DATE: <u> </u>	
DESIGNED BY: <u> </u>	CHECKED BY: <u> </u>	
IN CHARGE: <u> </u>	APPROVED BY: <u> </u>	
CITY OF MARLBETTA PARKING DECK CONCRETE REPAIR DETAILS GENERAL LOCATION SHOWING PART B DAMAGED AREAS ON UNDERSIDE OF DECK, CRACKS, SPALLS, CORNERS, WALL 1, WALL 2, COUNTERTOP, CURBS, FLEERS AND HELICAL TIE BARS FOR WALL 3		